

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI-110 001,


No.F.6/DFS/MS/School/2024/SZ/ 728

Dated: 29/07/2024

FIRE SAFETY CERTIFICATE

Certified that the Education Point Convent School, Plot No.-3 & 4, Vikas Nagar, Som Bazar Road, New Delhi-110059, comprised of ground floor plus three upper floors, owned/occupied by Education Point Convent School was issued FSC by this department vide letter no. F.6/DFS/MS/School/2021/SZ/539 dated 27.07.2021. The School building was re-inspected by the officer concerned of this department on 17.07.2024 in the presence of Sh. Vivek Tyagi (Admin.) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" w.e.f. 29/07/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 29/07/2024 at New Delhi.



Atul Garg
Director
Delhi Fire Service


Copy to:-

1. The Chairman, Education Point Convent School, Plot No.-3 & 4, Vikas Nagar, Som Bazar Road, New Delhi-110059.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi - 110054.

Following fire safety directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.


Manager
Education Point Convent School
Recognised & Affiliated to C.B.S.E.
Plot No. 3 & 4, Vikas Nagar
Som Bazar Road, New Delhi-110059


Principal
Education Point Convent School
Recognised & Affiliated to C.B.S.E.
Plot No. 3 & 4, Vikas Nagar
Som Bazar Road, New Delhi-110059