


"STOP CORONA VIRUS Wash Your Hand/Wear Mask/Maintain Social Distancing"



**DELHI JAL BOARD  
(GOVT. OF N.C.T. DELHI)  
QUALITY CONTROL LABORATORY  
WATER TREATMENT PLANT NANGLOI, DELHI-110041**

Water sample collected from M/S Education Point Convent School , Plot No ,3 & 4, Vikas Nagar , Som Bazar Road, New Delhi -110059 Vide Challan no 1720 dated 16.12.2024

S. No.	Particulars	Units	Limit		S1
			Acceptable	Permissible	
<b>PHYSICAL EXAMINATION</b>					
1.	Date of collection	--	--	--	19.12.2024
2.	Date of analysis	--	--	--	26.12.2024
3.	Colour	Hazen	5.0	15	Clear
4.	Odor	--	No Objectionable		No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	0.4
6.	PH value	--	6.5	8.5	4.5
7.	Electrical Conductivity	µmho	--	--	Nil
8.	Total dissolved solids	mg/l	500	2000	430
<b>CHEMICAL EXAMINATION</b>					
9.	Phenolphthalein Alkalinity	mg/l	--	--	Nil
10.	Total Alkalinity	mg/l	200	600	130
11.	Total Hardness	mg/l	200	600	150
12.	Calcium Hardness	mg/l	--	--	Nil
13.	Magnesium Hardness	mg/l	--	--	Nil
14.	Calcium as Ca	mg/l	75	200	50
15.	Magnesium as Mg	mg/l	30	100	15
16.	Ammonia as N	mg/l	0.5	N.R.	0.3
17.	Nitrite as N	mg/l	--	--	Nil
18.	Nitrate as NO <sub>3</sub>	mg/l	45	N.R.	15
19.	Sulphate	mg/l	200	400	110
20.	Chloride	mg/l	250	1000	120
21.	Dissolved Iron	mg/l	0.3	N.R.	0.1
22.	Fluoride	mg/l	1	1.5	0.01
23.	Fluoride	mg/l	0.05	N.R.	<0.001
24.	Cyanide	mg/l	0.20	1.0	0.1
<b>BACTERIOLOGICAL EXAMINATION</b>					
25.	Coli-form per 100 ml at 37°C	MPN	0	0	0

REMARKS: On the basis of above tested parameters, the sample S-1 can be use for drinking purpose.

Chemist

Manager

Education Point Convent School  
Recognised & Affiliated to C.B.S.E.  
Plot No. 3 & 4, Vikas Nagar  
Som Bazar Road, New Delhi-110059

Principal

Education Point Convent School  
Recognised & Affiliated to C.B.S.E.  
Plot No. 3 & 4, Vikas Nagar  
Som Bazar Road, New Delhi-110059

Aastt. Chief Water Analyst

DELHI JAL BOARD


Govt. of N.C.T. Delhi

Quality Control Laboratory

Water Works, Nangloi, Delhi-41



MUNICIPAL CORPORATION OF DELHI  
PUBLIC HEALTH DEPARTMENT, WEST ZONE  
DR. SAHIB SINGH VERMA NIGAM BHAWAN  
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



No.DHO/WZ/2024/D- 1968

Dated: 16/12/24

**HEALTH CERTIFICATE**

1. Name of the School Education Point Convent School
2. School address Plot No.3 & 4, Vikas Nagar Som Bazar Road New Delhi-110059.
3. No of shifts 01 Timing 08.00 AM TO 2.00 PM
4. No of students:- Boys 808 Girls 539 Total 1347
5. No of staff: - Male 07 Female 53 Total 60

**Accommodation provide for classroom as under:-**

- Floor area in the classroom is sufficient /insufficient Sufficient
- Classes are well lighted/ ill lighted Well lighted
- Classrooms are well ventilated/ill ventilated Well ventilated
- Classes are kept/ not kept neat and clean Neat & clean
- Building/ classrooms require/ do not require white wash etc. not required
- Drinking water is wholesome/ not wholesome wholesome
- Latrine arrangement is sanitary/ insanitary Sanitary from health point of view

**Note:- Valid for one year from the date of issue**

16/12/24  
Dy. Health Officer  
West Zone  
Dy Health Officer  
West Zone  
MCD

[Signature]  
Manager  
Education Point Convent School  
Recognised & Affiliated to C.B.S.E.  
Plot No. 3 & 4, Vikas Nagar  
Som Bazar Road, New Delhi-110059

[Signature]  
Principal  
Education Point Convent School  
Recognised & Affiliated to C.B.S.E.  
Plot No. 3 & 4, Vikas Nagar  
Som Bazar Road, New Delhi-110059