




MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT, WEST ZONE
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



NO. DHOWZ/2025/D-2205

Dated: 12/12/25


HEALTH CERTIFICATE


1. Name of the School Education Point Convent School
2. School Address Plot No-3 & 4 Vikas Nagar Som Bazar Road New Delhi-110059
3. No. of shifts 01 Timing 08 AM to 02 PM
4. No. of Students: Boys 865 Girls 605 Total 1470
5. No. of Staff: Gents 09 Ladies 63 Total 72


Accommodations provide for classroom as under:-

- Floor area in the classroom is sufficient/ not sufficient Sufficient
- Classes are well lighted/ill lighted Well lighted
- Classrooms are well ventilated/ill ventilated Well ventilated
- Classes are kept/ not kept neat and clean neat & clean
- Building/ classrooms require/ don not require white wash etc. not required
- Drinking water is wholesome/ not wholesome wholesome
- Latrine arrangement is sanitary/ insanitary sanitary from health point of view

This certificate is issued for sanitary and hygienic conditions from the health point of view of the school premises. This certificate has no bearing structure stability unauthorized construction and fire safety. This certificate is valid for one year from date of issue.


Manager
Education Point Convent School
Recognised & Affiliated to C.B.S.E.
Plot No. 3 & 4, Vikas Nagar
Som Bazar Road, New Delhi-110059


Principal
Education Point Convent School
Recognised & Affiliated to C.B.S.E.
Plot No. 3 & 4, Vikas Nagar
Som Bazar Road, New Delhi-110059


Dy. Health Officer
West Zone
Dy. Health Officer
West Zone



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI, DELHI-110041




Water Sample Analysis report of samples collected from "Education Point Convent School" Plot No 03 & 04, Vikas Nagar, Som Bazar Road, New Delhi - 110059 vide Challan No. 32 Dt-27.04.2026.

S1:- Bore Water at above site.

S2:- Drinking Point with (R.O.) at above site.

S. No.	Particulars	Units	Limit		S1	S2
			Acceptable	Permissible		
<p>THE TEST REPORT IS FOR THIS PARTICULAR WATER SAMPLE ONLY.</p> <p style="text-align: center;">PHYSICAL EXAMINATION</p>						
1.	Date of collection	-----	--	--	29.05.2026	
2.	Date of Analysis	-----	--	--	02.06.2026	
3.	Colour	CU	5.0	15	Clear	Clear
4.	Odour	-----	No. Objectionable		No Obj.	No Obj
5.	Turbidity	N.T.U.	1.0	5.0	2.0	0.80
6.	PH value	-----	6.5	8.5	7.2	6.8
7.	Electrical Conductivity	µmho/cm	--	--	2298	124.2
8.	Total dissolved solids	mg/l	500	2000	1493.7	80.7
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	mg/l	--	--	NIL	NIL
10.	Total Alkalinity	mg/l	200	600	390	20
11.	Total Hardness	mg/l	200	600	564	18
12.	Calcium Hardness	mg/l	--	--	258	06
13.	Magnesium Hardness	mg/l	--	--	311	12
14.	Calcium as Ca	mg/l	75	200	103.2	2.4
15.	Magnesium as Mg	mg/l	30	100	74.64	2.88
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l	---	--	NIL	NIL
18.	Nitrate as No ₃	mg/l	45	N.R.	25.9	1.6
19.	Sulphate	mg/l	200	400	126	14
20.	Chloride	mg/l	250	1000	362	24
21.	Fluoride	mg/l	1	1.50	0.40	0.08
22.	Dissolve Iron	mg/l	1	N.R.	0.24	ND
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20(min)	1.0	NIL	Nil
BACTERIOLOGICAL EXAMINATION						
25.	Coli-form per 100 ml at 37°C	MPN	0		39	0



REMARKS:- As per the tested parameters Sample-S1 is found Unsatisfactory & cannot be used for drinking purpose whereas Sample - S2 is found Satisfactory and can be used for drinking purpose.

Asst. A.C.W.A. Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works Nangloi, Delhi-110041

CHEMIST
Manager
Education Point Convent School
Recognised & Affiliated to C.B.S.E.
Plot No. 3 & 4, Vikas Nagar
Som Bazar Road, New Delhi-110059

A/BAGT.
Principal
Education Point Convent School
Recognised & Affiliated to C.B.S.E.
Plot No. 3 & 4, Vikas Nagar
Som Bazar Road, New Delhi-110059